

# Gates Mills Fire Department

1470 Chagrin River Road Gates Mills, Ohio 44040

P. Thomas Robinson, Fire Chief

Office 440-423-1580

---

## RUN SUMMARY / JULY 2015

- July 4, 2015 2085 Woodstock Road. Fire alarm.
- July 7, 2015 7875 Old Mill Road. Fire alarm.
- July 7, 2015 1491 Chagrin River Road. Power lines arcing.
- July 9, 2015 7150 Old Mill Road. Fire alarm.
- July 11, 2015 501 Chagrin River Road. Motor vehicle crash with injuries.
- July 11, 2015 7665 Old Mill Road. Carbon Monoxide alarm.
- July 14, 2015 8801 Kinsman Road, Russell. Hillcrest Technical Rescue Team activation for a Swift Water Rescue. Three people and twelve dogs were rescued from a structure surrounded by three to four foot deep fast moving flood waters.
- July 14, 2015 Intersection of Chagrin River Road and Mayfield Road. Wash-down needed to remove mud following heavy rain and flooding.
- July 16, 2015 1501 Chagrin River Road. Trouble alarm due to a faulty telephone line.
- July 16, 2015 7621 Old Mill Road. Fire alarm due to burnt food on the stove.
- July 21, 2015 1491 Chagrin River Road (Gates Mills Library). Fire alarm with smoke reported in the structure. Smoke due to a HVAC blower that overheated and melted the plastic housing surrounding the motor.
- July 21, 2015 7839 Gates Mills Estates Drive. Public assist (smoke alarm installation).
- July 22, 2015 1760 Chartley Road. Fire alarm.
- July 24, 2015 35149 Dorchester Road. Fire alarm.
- July 27, 2015 7165 Settlers Ridge. Fire alarm.

**TOTAL MONTHLY RESPONSES:** **15**

---

The July training topics were:

- July 4, 2015 Vehicle checks on E-1411, E-1412, E-1413 and C-1472.  
Drivers training.
- July 29, 2015 Vehicle checks on E-1411, E-1412, E-1413 and C-1472.  
New Self Contained Breathing Apparatus (SCBA) units were installed on E-1411, E-1412 and E-1413 and placed in-service.

**Ambulance provided by Mayfield Village Fire Department.** **20**

---